

## VSG WICKET GATE GREASE LINCOLN VENTMETER TEST

Test Temperature (°C)	Vent Pressure Reading after 30 seconds <sup>(1)</sup>	
	Test kPa	HQ Specification kPa maximum
25	0	1,250
0	0	2,800
-18	0	7,000

**Note:** In this test the device is pressurized to 12,400 kPa (1800 psi) and the pressure remaining after 30 seconds is recorded. A high pressure remaining is considered indicative of a grease that may not flow readily.

Conversely, a low pressure shows that the grease was still mobile and would flow. Zero pressure (ie. VSG) is considered excellent.